



☎ 91 - 261 (o) : S.M.C. : 2423750 TO 56, FAX: 2451935 / 2422110, FIRE CONTROL- 2414195-96

To, [Renewal]
The Principal
SHANTI ASIATIC SCHOOL
421-427, Olpad - Dandi Road
New Narthan Town, Tal: Olpad, Dist: Surat -395 005

Sub :- Inspection of Fire Fighting System in your SHANTI ASIATIC SCHOOL, 421- 427, Olpad - Dandi Road , New Narthan Town, Tal: Olpad, Dist: Surat.

Ref :- Your letter No. Nill, Dated: 31-01-2019.

Sir,

With reference to the above, SHANTI ASIATIC SCHOOL, 421- 427, Olpad - Dandi Road , New Narthan Town, Tal: Olpad, Dist: Surat was inspected by this dept. on Date: 01-02-2019. During inspection of the said premises , following system were found adequate & in working condition.

1.	Landing valve [Hydrant]	Every Floor	Yes
2.	Hose Box [with Hose & Nozzle]	04 Nos.	Yes
3.	Hose Reel	04 Nos.	Yes
4.	DCP Fire Extinguishers	05 Kgs. Capacity	08 Nos.
5.	Co2 Fire Extinguishers	02 Kgs. Capacity	07 Nos.
6.	EXIT , ASSEMBLY POINT Marking	-----	Yes
7.	Over Head Water Tank	Capacity	20,000 Ltrs.
8.	Under Ground Water Tank	Capacity	1,00,000 Ltrs.

- (01) In case of Emergency, Fire Safety System must be operated by your trained person immediately.
- (02) The Fire dept. of SMC will not be responsible for any loss of life & property due to Fire / Emergency incident inside your premises.
- (03) Our Fire Certificate is limited to Fire Fighting Systems available in your premises only. You are here by advised to maintain the above system in good working condition.
- (04) Any other instructions given by fire dept. from time to time about fire safety of the premises to be followed.
- (05) This certificate is valid for one year from the date of issue.
- (06) The administrative charges of Rs. 500 /- has been recovered vide R. No.161/14, Dated: 01-02-2019.

No.FES/ NOC/Outward/ No. 2130

Date: 13 - 02 - 2019



Chief Fire Officer
Fire & Emergency Services
Surat Municipal Corporation

Principal
Shanti Asiatic School
Olpad Dandi Road, Surat.